

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 506 / १० वी ३४ / १५-२१

Dated: 03/02/26

It is certified that an inspection team headed by Harsh Vardhan(Name of Officers with designation) from J.E. (Jal) N.P.P. Hathras(Name of Department/ Office) inspected the Tal Kal. Vibhag N.P.P. Hathras

(Name & Address of the school) on 13/01/2026(date of inspection) and found that the A.B.G. BUNUKULAM (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of only seso year (1 year)Signature with Seal: [Signature]Name: अवर अभियन्ता (जल)
Harsh VardhanDesignation: अवर अभियन्ता (जल)Name & Address of the Office / Department: Tal Kal. VilN.P.P Hathras

To

A.B.G. BUNUKULAMMahmoodpur, Block: Sasni, Hathras

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



SV TESTING LABORATORIES PVT LTD

Because Quality Matters.....



Laboratory: 0340K, Jaipura, Bisrakh, Near Kisan Chowk, Greater Noida, G.B Nagar, U.P.-201306.

Contact: +91+120-6256189, 9910830469, 7011958624, 9927214385

svtestinglaboratories@gmail.com, svtlab7@gmail.com

https://svtestinglaboratories.co.in/

MSME No.: UP-28-0145-056

(N.A.B.L. ACCREDITED, ISO 9001:2015 CERTIFIED LABORATORY)

TEST REPORT

Issued To:- ABG GURUKULAM Mahmoodpur Barse, Sasni Distt- Hathras(U.P.)- 204216 Description:- R.O. Drinking Water Sample Qty:- Approx. 2 Ltrs.	Discipline:- Chemical Group:- Water URL No:- TC17209260000038F Report No:- SVTL/20-260110-01 Reporting Date: 13.01.2026 Sample Received On: 10.01.2026 Sampled By: Customer. Analysis Start Date: 10.01.2026 Analysis End Date: 13.01.2026
--	---

Page No: 01 of 01

RESULT

S.N.	TEST PARAMETERS (With unit of measurement)	TEST RESULT	TEST METHOD	REQUIREMENT AS PER IS: 10500-2012 (RA-2018)	
				ACCEPTABLE LIMIT	PERMISSIBLE LIMIT
General Parameters:-					
1	PH	7.18	APHA 24 th Edition 4500	6.5 to 8.5	No Relaxation
2	Sulphate, mg/l	4.2	APHA 24 th Edition 4500	200 Max.	400 Max.
3	Magnesium, mg/l	2.3	APHA 24 th Edition 3500	30 Max.	100 Max.
4	Electrical Conductivity, μ s/cm	170	IS:3025 (Part-14)	-	-
5	Turbidity, NTU	0.1	APHA 24 th Edition 2130	1.0 Max.	5 Max.
6	Total Hardness (as CaCO ₃), mg/l	35.3	APHA 24 th Edition 2340	200 Max.	600 Max.
7	Calcium as Ca, mg/l	10.4	APHA 24 th Edition 3500	75 Max.	200 Max.
8	Chloride as Cl, mg/l	16.0	APHA 24 th Edition 4500	250 Max.	1000 Max.
9	Total Residual Chlorine, mg/l	ND	APHA 24 th Edition 4500	-	-
10	Iron as Fe, mg/l	ND (DL-0.05)	APHA 24 th Edition 3500	0.3 Max.	No Relaxation
11	Fluoride as F, mg/l	ND (DL-0.05)	APHA 24 th Edition 4500	1.0 Max.	1.5 Max.
12	Total Alkalinity, mg/l	30.7	APHA 24 th Edition 2320	200 Max.	600 Max.
13	Total Dissolved Solid (TDS), mg/l	110	APHA 24 th Edition 2540	500 Max.	2000 Max.

Note:-N.D. (Not detected), Value enclosed in brackets are the detection limit.

Remarks: - The Sample Confirms to IS: 10500-2012 (RA-2018) With respect to above test only.

End of Report

Checked By



Terms & Conditions :

1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed after 30 days from the date